

AENOR

AENOR Product Certificate Low Voltage Material



030/002416

AENOR certifies that the organization

GEWISS, S.P.A.

registered office VIA ALESSANDRO VOLTA, 1 24069 CENATE SOTTO (Bergamo - Italia)

supplies Circuit-Breakers for overcurrent protection for household and similar installation

in compliance with UNE-EN 60898-1:2004 (EN 60898-1:2003; EN 60898-1:2003 CORR:2004)
UNE-EN 60898-1:2004/A11:2006 (EN 60898-1:2003/A11:2005)
UNE-EN 60898-1:2004/A1:2005 (EN 60898-1:2003/A1:2004)
UNE-EN 60898-1:2004/A12:2009 (EN 60898-1:2003/A12:2008)
UNE-EN 60898-1:2004/A13:2013 (EN 60898-1:2003/A13:2012)

References Specified in Annex to the Certificate

Production site ZONA INDUSTRIAL 2ª FASE - BUSTELO P 4560-709 PENAFIEL (Portugal)

Certification scheme In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP 030.15.

This certificate supersedes 030/002416, dated 2015-09-16

First issued on 2015-09-16
Modified on 2017-12-14
Validity date 2020-09-16

A handwritten signature in blue ink, appearing to read 'Rafael GARCÍA MEIRO'.

Rafael GARCÍA MEIRO
Chief Executive Officer

AENOR

AENOR Product Certificate Low Voltage Material

030/002416

Annex to Certificate

Trade mark: GEWISS

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
GW91727	1P+N	230 V-	6 A	6000 A	6000 A	3	C
GW91728	1P+N	230 V-	10 A	6000 A	6000 A	3	C
GW91729	1P+N	230 V-	13 A	6000 A	6000 A	3	C
GW91730	1P+N	230 V-	16 A	6000 A	6000 A	3	C
GW91731	1P+N	230 V-	20 A	6000 A	6000 A	3	C
GW91732	1P+N	230 V-	25 A	6000 A	6000 A	3	C
GW91733	1P+N	230 V-	32 A	6000 A	6000 A	3	C
GW91734	1P+N	230 V-	40 A	6000 A	6000 A	3	C
GW91735	1P+N	230 V-	50 A	6000 A	6000 A	3	C
GW91736	1P+N	230 V-	63 A	6000 A	6000 A	3	C
GW91747	2P	400 V-	6 A	6000 A	6000 A	3	C
GW91748	2P	400 V-	10 A	6000 A	6000 A	3	C
GW91749	2P	400 V-	13 A	6000 A	6000 A	3	C
GW91750	2P	400 V-	16 A	6000 A	6000 A	3	C
GW91751	2P	400 V-	20 A	6000 A	6000 A	3	C
GW91752	2P	400 V-	25 A	6000 A	6000 A	3	C
GW91753	2P	400 V-	32 A	6000 A	6000 A	3	C
GW91754	2P	400 V-	40 A	6000 A	6000 A	3	C
GW91755	2P	400 V-	50 A	6000 A	6000 A	3	C
GW91756	2P	400 V-	63 A	6000 A	6000 A	3	C
GW92001	1P	230/400 V-	1 A	6000 A	6000 A	3	C
GW92002	1P	230/400 V-	2 A	6000 A	6000 A	3	C
GW92003	1P	230/400 V-	3 A	6000 A	6000 A	3	C
GW92004	1P	230/400 V-	4 A	6000 A	6000 A	3	C
GW92005	1P	230/400 V-	6 A	6000 A	6000 A	3	C
GW92006	1P	230/400 V-	10 A	6000 A	6000 A	3	C

Original Electronic Certificate

First issued on 2015-09-16
Modified on 2017-12-14
Validity date 2020-09-16

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

AENOR Product Certificate Low Voltage Material

030/002416

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
GW92007	1P	230/400 V-	16 A	6000 A	6000 A	3	C
GW92008	1P	230/400 V-	20 A	6000 A	6000 A	3	C
GW92009	1P	230/400 V-	25 A	6000 A	6000 A	3	C
GW92010	1P	230/400 V-	32 A	6000 A	6000 A	3	C
GW92011	1P	230/400 V-	40 A	6000 A	6000 A	3	C
GW92012	1P	230/400 V-	50 A	6000 A	6000 A	3	C
GW92013	1P	230/400 V-	63 A	6000 A	6000 A	3	C
GW92014	1P	230/400 V-	13 A	6000 A	6000 A	3	C
GW92021	1P+N	230 V-	1 A	6000 A	6000 A	3	C
GW92022	1P+N	230 V-	2 A	6000 A	6000 A	3	C
GW92023	1P+N	230 V-	3 A	6000 A	6000 A	3	C
GW92024	1P+N	230 V-	4 A	6000 A	6000 A	3	C
GW92025	1P+N	230 V-	6 A	6000 A	6000 A	3	C
GW92026	1P+N	230 V-	10 A	6000 A	6000 A	3	C
GW92027	1P+N	230 V-	16 A	6000 A	6000 A	3	C
GW92028	1P+N	230 V-	20 A	6000 A	6000 A	3	C
GW92029	1P+N	230 V-	25 A	6000 A	6000 A	3	C
GW92030	1P+N	230 V-	32 A	6000 A	6000 A	3	C
GW92031	1P+N	230 V-	40 A	6000 A	6000 A	3	C
GW92032	1P+N	230 V-	50 A	6000 A	6000 A	3	C
GW92033	1P+N	230 V-	63 A	6000 A	6000 A	3	C
GW92034	1P+N	230 V-	13 A	6000 A	6000 A	3	C
GW92041	2P	400 V-	1 A	6000 A	6000 A	3	C
GW92042	2P	400 V-	2 A	6000 A	6000 A	3	C
GW92043	2P	400 V-	3 A	6000 A	6000 A	3	C
GW92044	2P	400 V-	4 A	6000 A	6000 A	3	C
GW92045	2P	400 V-	6 A	6000 A	6000 A	3	C
GW92046	2P	400 V-	10 A	6000 A	6000 A	3	C

Original Electronic Certificate

First issued on 2015-09-16
Modified on 2017-12-14
Validity date 2020-09-16

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

AENOR Product Certificate Low Voltage Material

030/002416

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
GW92047	2P	400 V-	16 A	6000 A	6000 A	3	C
GW92048	2P	400 V-	20 A	6000 A	6000 A	3	C
GW92049	2P	400 V-	25 A	6000 A	6000 A	3	C
GW92050	2P	400 V-	32 A	6000 A	6000 A	3	C
GW92051	2P	400 V-	40 A	6000 A	6000 A	3	C
GW92052	2P	400 V-	50 A	6000 A	6000 A	3	C
GW92053	2P	400 V-	63 A	6000 A	6000 A	3	C
GW92054	2P	400 V-	13 A	6000 A	6000 A	3	C
GW92061	3P	400 V-	1 A	6000 A	6000 A	3	C
GW92062	3P	400 V-	2 A	6000 A	6000 A	3	C
GW92063	3P	400 V-	3 A	6000 A	6000 A	3	C
GW92064	3P	400 V-	4 A	6000 A	6000 A	3	C
GW92065	3P	400 V-	6 A	6000 A	6000 A	3	C
GW92066	3P	400 V-	10 A	6000 A	6000 A	3	C
GW92067	3P	400 V-	16 A	6000 A	6000 A	3	C
GW92068	3P	400 V-	20 A	6000 A	6000 A	3	C
GW92069	3P	400 V-	25 A	6000 A	6000 A	3	C
GW92070	3P	400 V-	32 A	6000 A	6000 A	3	C
GW92071	3P	400 V-	40 A	6000 A	6000 A	3	C
GW92072	3P	400 V-	50 A	6000 A	6000 A	3	C
GW92073	3P	400 V-	63 A	6000 A	6000 A	3	C
GW92074	3P	400 V-	13 A	6000 A	6000 A	3	C
GW92081	4P	400 V-	1 A	6000 A	6000 A	3	C
GW92082	4P	400 V-	2 A	6000 A	6000 A	3	C
GW92083	4P	400 V-	3 A	6000 A	6000 A	3	C
GW92084	4P	400 V-	4 A	6000 A	6000 A	3	C
GW92085	4P	400 V-	6 A	6000 A	6000 A	3	C
GW92086	4P	400 V-	10 A	6000 A	6000 A	3	C

Original Electronic Certificate

First issued on 2015-09-16
Modified on 2017-12-14
Validity date 2020-09-16

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

AENOR Product Certificate Low Voltage Material

030/002416

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
GW92087	4P	400 V-	16 A	6000 A	6000 A	3	C
GW92088	4P	400 V-	20 A	6000 A	6000 A	3	C
GW92089	4P	400 V-	25 A	6000 A	6000 A	3	C
GW92090	4P	400 V-	32 A	6000 A	6000 A	3	C
GW92091	4P	400 V-	40 A	6000 A	6000 A	3	C
GW92092	4P	400 V-	50 A	6000 A	6000 A	3	C
GW92093	4P	400 V-	63 A	6000 A	6000 A	3	C
GW92094	4P	400 V-	13 A	6000 A	6000 A	3	C
GW92205	1P	230/400 V-	6 A	6000 A	6000 A	3	B
GW92206	1P	230/400 V-	10 A	6000 A	6000 A	3	B
GW92207	1P	230/400 V-	16 A	6000 A	6000 A	3	B
GW92208	1P	230/400 V-	20 A	6000 A	6000 A	3	B
GW92209	1P	230/400 V-	25 A	6000 A	6000 A	3	B
GW92210	1P	230/400 V-	32 A	6000 A	6000 A	3	B
GW92211	1P	230/400 V-	40 A	6000 A	6000 A	3	B
GW92212	1P	230/400 V-	50 A	6000 A	6000 A	3	B
GW92213	1P	230/400 V-	63 A	6000 A	6000 A	3	B
GW92214	1P	230/400 V-	13 A	6000 A	6000 A	3	B
GW92245	2P	400 V-	6 A	6000 A	6000 A	3	B
GW92246	2P	400 V-	10 A	6000 A	6000 A	3	B
GW92247	2P	400 V-	16 A	6000 A	6000 A	3	B
GW92248	2P	400 V-	20 A	6000 A	6000 A	3	B
GW92249	2P	400 V-	25 A	6000 A	6000 A	3	B
GW92250	2P	400 V-	32 A	6000 A	6000 A	3	B
GW92251	2P	400 V-	40 A	6000 A	6000 A	3	B
GW92252	2P	400 V-	50 A	6000 A	6000 A	3	B
GW92253	2P	400 V-	63 A	6000 A	6000 A	3	B
GW92254	2P	400 V-	13 A	6000 A	6000 A	3	B

Original Electronic Certificate

First issued on 2015-09-16
Modified on 2017-12-14
Validity date 2020-09-16

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

AENOR Product Certificate Low Voltage Material

030/002416

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
GW92265	3P	400 V-	6 A	6000 A	6000 A	3	B
GW92266	3P	400 V-	10 A	6000 A	6000 A	3	B
GW92267	3P	400 V-	16 A	6000 A	6000 A	3	B
GW92268	3P	400 V-	20 A	6000 A	6000 A	3	B
GW92269	3P	400 V-	25 A	6000 A	6000 A	3	B
GW92270	3P	400 V-	32 A	6000 A	6000 A	3	B
GW92271	3P	400 V-	40 A	6000 A	6000 A	3	B
GW92272	3P	400 V-	50 A	6000 A	6000 A	3	B
GW92273	3P	400 V-	63 A	6000 A	6000 A	3	B
GW92274	3P	400 V-	13 A	6000 A	6000 A	3	B
GW92285	4P	400 V-	6 A	6000 A	6000 A	3	B
GW92286	4P	400 V-	10 A	6000 A	6000 A	3	B
GW92287	4P	400 V-	16 A	6000 A	6000 A	3	B
GW92288	4P	400 V-	20 A	6000 A	6000 A	3	B
GW92289	4P	400 V-	25 A	6000 A	6000 A	3	B
GW92290	4P	400 V-	32 A	6000 A	6000 A	3	B
GW92291	4P	400 V-	40 A	6000 A	6000 A	3	B
GW92292	4P	400 V-	50 A	6000 A	6000 A	3	B
GW92293	4P	400 V-	63 A	6000 A	6000 A	3	B
GW92294	4P	400 V-	13 A	6000 A	6000 A	3	B
GW92405	1P	230/400 V-	6 A	6000 A	6000 A	---	D
GW92406	1P	230/400 V-	10 A	6000 A	6000 A	---	D
GW92407	1P	230/400 V-	16 A	6000 A	6000 A	---	D
GW92408	1P	230/400 V-	20 A	6000 A	6000 A	---	D
GW92409	1P	230/400 V-	25 A	6000 A	6000 A	---	D
GW92410	1P	230/400 V-	32 A	6000 A	6000 A	---	D
GW92411	1P	230/400 V-	40 A	6000 A	6000 A	---	D
GW92414	1P	230/400 V-	13 A	6000 A	6000 A	---	D

First issued on 2015-09-16
Modified on 2017-12-14
Validity date 2020-09-16

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

AENOR Product Certificate Low Voltage Material

030/002416

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
GW92445	2P	400 V-	4 A	6000 A	6000 A	---	D
GW92446	2P	400 V-	10 A	6000 A	6000 A	---	D
GW92447	2P	400 V-	16 A	6000 A	6000 A	---	D
GW92448	2P	400 V-	20 A	6000 A	6000 A	---	D
GW92449	2P	400 V-	25 A	6000 A	6000 A	---	D
GW92450	2P	400 V-	32 A	6000 A	6000 A	---	D
GW92451	2P	400 V-	40 A	6000 A	6000 A	---	D
GW92454	2P	400 V-	13 A	6000 A	6000 A	---	D
GW92465	3P	400 V-	6 A	6000 A	6000 A	---	D
GW92466	3P	400 V-	10 A	6000 A	6000 A	---	D
GW92467	3P	400 V-	16 A	6000 A	6000 A	---	D
GW92468	3P	400 V-	20 A	6000 A	6000 A	---	D
GW92469	3P	400 V-	25 A	6000 A	6000 A	---	D
GW92470	3P	400 V-	32 A	6000 A	6000 A	---	D
GW92471	3P	400 V-	40 A	6000 A	6000 A	---	D
GW92474	3P	400 V-	13 A	6000 A	6000 A	---	D
GW92485	4P	400 V-	6 A	6000 A	6000 A	---	D
GW92486	4P	400 V-	10 A	6000 A	6000 A	---	D
GW92487	4P	400 V-	16 A	6000 A	6000 A	---	D
GW92488	4P	400 V-	20 A	6000 A	6000 A	---	D
GW92489	4P	400 V-	25 A	6000 A	6000 A	---	D
GW92490	4P	400 V-	32 A	6000 A	6000 A	---	D
GW92491	4P	400 V-	40 A	6000 A	6000 A	---	D
GW92494	4P	400 V-	13 A	6000 A	6000 A	---	D
GW93551	2P	400 V-	40 A	6000 A	6000 A	3	C
GW93625	1P+N	230 V-	6 A	6000 A	6000 A	3	C
GW93626	1P+N	230 V-	10 A	6000 A	6000 A	3	C
GW93627	1P+N	230 V-	16 A	6000 A	6000 A	3	C

First issued on 2015-09-16
Modified on 2017-12-14
Validity date 2020-09-16

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

AENOR Product Certificate Low Voltage Material

030/002416

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
GW93628	1P+N	230 V-	20 A	6000 A	6000 A	3	C
GW93629	1P+N	230 V-	25 A	6000 A	6000 A	3	C
GW93630	1P+N	230 V-	32 A	6000 A	6000 A	3	C
GW93631	1P+N	230 V-	40 A	6000 A	6000 A	3	C
GW93632	1P+N	230 V-	50 A	6000 A	6000 A	3	C
GW93633	1P+N	230 V-	63 A	6000 A	6000 A	3	C
GW93645	2P	400 V-	6 A	6000 A	6000 A	3	C
GW93646	2P	400 V-	10 A	6000 A	6000 A	3	C
GW93647	2P	400 V-	16 A	6000 A	6000 A	3	C
GW93648	2P	400 V-	20 A	6000 A	6000 A	3	C
GW93649	2P	400 V-	25 A	6000 A	6000 A	3	C
GW93650	2P	400 V-	32 A	6000 A	6000 A	3	C
GW93651	2P	400 V-	40 A	6000 A	6000 A	3	C
GW93652	2P	400 V-	50 A	6000 A	6000 A	3	C
GW93653	2P	400 V-	63 A	6000 A	6000 A	3	C
GW93665	3P	400 V-	6 A	6000 A	6000 A	3	C
GW93666	3P	400 V-	10 A	6000 A	6000 A	3	C
GW93667	3P	400 V-	16 A	6000 A	6000 A	3	C
GW93668	3P	400 V-	20 A	6000 A	6000 A	3	C
GW93669	3P	400 V-	25 A	6000 A	6000 A	3	C
GW93670	3P	400 V-	32 A	6000 A	6000 A	3	C
GW93671	3P	400 V-	40 A	6000 A	6000 A	3	C
GW93672	3P	400 V-	50 A	6000 A	6000 A	3	C
GW93673	3P	400 V-	63 A	6000 A	6000 A	3	C
GW93685	4P	400 V-	6 A	6000 A	6000 A	3	C
GW93686	4P	400 V-	10 A	6000 A	6000 A	3	C
GW93687	4P	400 V-	16 A	6000 A	6000 A	3	C
GW93688	4P	400 V-	20 A	6000 A	6000 A	3	C

Original Electronic Certificate

First issued on 2015-09-16
Modified on 2017-12-14
Validity date 2020-09-16

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

AENOR Product Certificate Low Voltage Material

030/002416

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
GW93689	4P	400 V-	25 A	6000 A	6000 A	3	C
GW93690	4P	400 V-	32 A	6000 A	6000 A	3	C
GW93691	4P	400 V-	40 A	6000 A	6000 A	3	C
GW93692	4P	400 V-	50 A	6000 A	6000 A	3	C
GW93693	4P	400 V-	63 A	6000 A	6000 A	3	C

Original Electronic Certificate

First issued on 2015-09-16
Modified on 2017-12-14
Validity date 2020-09-16

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com