



ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **21233-002-02**

Valid from: 2022 09 07
until: 2024 09 07

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **GEWISS SPA**
Via A. Volta 1
24069 Cenate Sotto (Bergamo)
Italy

Product: **Residual current operated circuit-breakers (RCCBs)
with automatic test device**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **3387-1766/18**

Österreichischer Verband für Elektrotechnik
Head of OVE Certification

T. Neumayer

Digitally signed by T. Neumayer
Email=t.neumayer@ove.at

Dipl.-Ing. T. Neumayer

Wien, 2022 07 28



OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



Manufacturer:

GEWISS SPA
Via A. Volta 1
24069 Cenate Sotto (Bergamo)
Italy

Factory location(s):

GEWISS Portugal - Industrial de Material Eléctrico Unipessoal, Limitada
Zona Industrial 2° fase
4560-043 Bustelo, Penafiel
Portugal

Tested and certified according to:

OVE EN 61008-1:2018-04-01
ÖVE EN 61008-2-1+A11:1998-06
OVE E 8601:2018-03-01

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

**Product: Residual current operated circuit-breakers (RCCBs)
with automatic test device**

Type designation:

Rating:

Trademark:

GW90931G

Rated voltage: AC 230 V
Rated current: 25 A
1P+N
30 mA, Type A, Type G
Im = 630 A; Inc = 10000 A
-25°C to +40°C
with AUTOTEST module

GEWISS

GW90932G

Rated voltage: AC 230 V
Rated current: 40 A
1P+N
30 mA, Type A, Type G
Im = 630 A; Inc = 10000 A
-25°C to +40°C
with AUTOTEST module

GEWISS

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

GW90933G

GEWISS

Rated voltage: AC 230 V

Rated current: 63 A

1P+N

30 mA, Type A, Type G

$I_m = 630 \text{ A}$; $I_{nc} = 10000 \text{ A}$

-25°C to +40°C

with AUTOTEST module

GW90941G

GEWISS

Rated voltage: AC 400 V

Rated current: 25 A

3P+N

30 mA, Type A, Type G

$I_m = 630 \text{ A}$; $I_{nc} = 10000 \text{ A}$

-25°C to +40°C

with AUTOTEST module

GW90942G

GEWISS

Rated voltage: AC 400 V

Rated current: 40 A

3P+N

30 mA, Type A, Type G

$I_m = 630 \text{ A}$; $I_{nc} = 10000 \text{ A}$

-25°C to +40°C

with AUTOTEST module

GW90943G

GEWISS

Rated voltage: AC 400 V

Rated current: 63 A

3P+N

30 mA, Type A, Type G

$I_m = 630 \text{ A}$; $I_{nc} = 10000 \text{ A}$

-25°C to +40°C

with AUTOTEST module

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.