

RCC (REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO
ACDC DYNAMICS
IN TERMS OF SANS 10142 CLAUSE 4.
ISSUED BY

National Regulator for Compulsory Specifications


PRODUCT: RESIDUAL CURRENT OPERATED CIRCUIT-BREAKERS WITHOUT INTEGRAL OVERCURRENT PROTECTION (GEWISS)

Series IDP (GWD40.., GWD42.., GWD46.., GWD44.., GWD48.., GWD41.., GWD43..); 230V; 400V; 25-40-63A; Inc/Δc=6000-1000A; 2P; 3P+N.

Test Laboratory:
IMQ

Test Report No(s): PB15A0429078-01-00

RCC No: 1706040


NRCSTech General Manager

In accordance to (Standards):
IEC 61008-1:2010

Period of Validity
27/06/2017 to 27/06/2020

DATE
10/07/2017

